

**DPSAL**

Testing for a better life

DPS**Analytical Laboratory Private Limited**G-7, Site No-3, Panki Industrial Area, Udyog Nagar
Kanpur, Uttar Pradesh - 208020 (India)Mobile: +91 7607 949 002, Email ID: dps@dpsalpl.in
CIN-U71200UP2024PTC207815/UDYAM-UP-43-0141084**Test Report**

Report ID: DPS260725011

Issued To	ST MOTHER TRESA'S SCHOOL	Sample Booking / Receipt Date	25/07/2026
Letter Ref No.	Nil	Date of Issue	29/07/2026
Date	25/07/2026		
Client Name	ST MOTHER TRESA'S SCHOOL, Affiliated to CBSE Delhi, Affiliation Number 2134170 Sarai Pratham, Achalda Road, Bidhuna P.O. Auraiya Dt.UP.-206243 Ph: 9412284115		
Kind Attention	Mr. Raju Francis Koippally	Sample Condition	Good
Email	motherteresabidhuna2020@gmail.com		
Sample Description	Drinking water		



ID: DPS2607250011N

Date of start of testing: 25.07.2026

Date of completion of testing: 29.07.2026

Sl. No.	Test Parameter	Observed Value	Specified value as per IS:10500-2012		Test method
			Desirable	Extended	
1..	Taste	Agreeable	Agreeable	Agreeable	IS:3025(P-8)-2023
2.	Turbidity, NTU	1.0	1	5	IS:3025(P-10)-2023
3.	Nitrate, mg/l	N/D	45	No relaxation	IS:3025(P-34)-Sec-1-2023

-----End of report-----



PRINCIPAL
St. Mother Teresa's School
Sarai Pratham, Achalda Road
Bidhuna, Auraiya Dt. (U.P.) 206243

MANAGER
St. Mother Teresa's School
Sarai Pratham, Achalda Road
Bidhuna, Auraiya Dt. (U.P.) 206243

Analyst

Reviewed by

*Subject to Terms & Conditions overleaf


Authorised Signatory
ISO 9001:2015 Certified Laboratory

**DPSAL**

Testing for a better life

DPS**Analytical Laboratory Private Limited**

G-7, Site No-3, Panki Industrial Area, Udyog Nagar

Kanpur, Uttar Pradesh - 208020 (India)

Mobile: +91 7607 949 002, Email ID: dps@dpsalpl.in

CIN-U71200UP2024PTC207815/UDYAM-UP-43-0141084



NABLT0726UP18580

ULRNABLT0726UP185802600000006

Page 1 of 1

Test Report

Report ID: DPS260725011				
Issued To	ST MOTHER TRESA'S SCHOOL	Sample Booking / Receipt Date	25/07/2026	
Letter Ref No.	Nil	Date of Issue	29/07/2026	
Date	25/07/2026			
Client Name	ST MOTHER TRESA'S SCHOOL , Affiliated to CBSE Delhi, Affiliation Number 2134170 Sarai Pratham, Achalda Road, Bidhuna P.O. Auraiya Dt.UP.-206243 Ph: 9412284115			
Kind Attention	Mr. Raju Francis Koippally		Sample Condition	
Email	motherteresabidhuna2020@gmail.com		Good	
Sample Description	Drinking water			

ID: DPS2607250011

Date of start of testing: 25.07.2026

Date of completion of testing: 29.07.2026

Sl. No.	Test Parameter	Observed Value	Specified value as per IS:10500-2012 RA-2023		Test method
			Desirable	Extended	
1.	Color, Hazen units	1.0	5	15	IS:3025(P-4)-2021
2.	Odor	Agreeable	Agreeable	Agreeable	IS:3025(P-5)-2018
3.	pH Value at 27°C	7.25	6.5 to 8.5		IS:3025(P-11)-2022
4.	Total Dissolved Solids, mg/l	308	500	2000	IS:3025(P-16)-2023
5.	Alkalinity(as CaCO ₃),mg/l	132.81	200	600	IS:3025(P-23)-2023
6.	Chlorides (as Cl), mg/l	63	250	1000	IS:3025(P-32)-2025
7.	Total Hardness (as CaCO ₃), mg/l	223.10	300	600	IS:3025(P-21)-2009
8.	Calcium, (as Ca), mg/l	32.06	30	100	IS: 3025(P-40)-2024
9.	Fluorides (as F), mg/l	0.67	1.0	1.5	IS: 3025(P-60)-2008 RA-2019
10.	Iron(as Fe), mg/l	0.67	0.3	No relaxation	IS: 3025(P-53)-2024
11.	Sulphate(as So ₄),mg/l	34.80	200	400	IS: 3025(P-24)-1986 RA-2019
12.	Magnesium(as mg),mg/l	2.48	30	100	IS:3025(P-46)-2023

-----End of report-----

PRINCIPAL
 St. Mother Teresa's School
 Sarai Pratham, Achalda Road
 Bidhuna, Auraiya Dt. (U.P.) 206243

MANAGER
 St. Mother Teresa's School
 Sarai Pratham, Achalda Road
 Bidhuna, Auraiya Dt. (U.P.) 206243

Analyst

Authorised Signatory

*Subject to Terms & Conditions overleaf

NABL Accredited & ISO 9001:2015 Certified Laboratory

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 01-09-26

It is certified that an inspection team headed by ...Mr. VIVEK KUMAR.....

(Name of Officers with designation) from BLOCK, OFFICE, BIDHUNA PHED

inspected the ST. MOTHER TERESA'S SCHOOL, BIDHUNA

(Name & Address of the school) on 01-09-26.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DPS 260725011..... dated 29-07-2026

of DPS, Analytical Lab, Pvt, Ltd. (PHED Lab) certified that the

ST. MOTHER TERESA'S SCHOOL.....(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01-09-27

Signature with Seal: अवर अभि. (नॉसिं)

Name : VIVEK KUMAR

Designation : JE (MID)

Name & Address of the Office / Department : BLOCK, BIDHUNA

To PRINCIPAL,

S.M.T.S., BIDHUNA

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

S. L. Singh
PRINCIPAL

St. Mother Teresa's School
Sarai Pratham, Achalda Road
Bidhuna, Auraiya Dt. (U.P.) 206243

Manoj Kumar
MANAGER

St. Mother Teresa's School
Sarai Pratham, Achalda Road
Bidhuna, Auraiya Dt. (U.P.) 206243